

Dr. Ramesh Chandra

PhD, M.B.A., M.Sc., P.G. Dip. (C&S), P.G. Dip. (F&L.S.A.), J.C.C. (England)
F.O.C.C. (U.K.), F.F.P.C. (U.K.), Grade I Fire E (India)
M.I. Fire E (England & India), F.I. Fire E (India)
Recipient of President's Fire Service Medal
for Gallantry Distinguished & Meritorious Services
Former State Chief Fire Officer, Govt. of Bihar
Sr. Fire Consultant, Advisor, Fire Auditor & Trainer

OFFICE :

Amba Residency, Ground floor,
East Boring Canal Road,
Patna - 800 001 (Bihar)
Mob 9471006572,
7979833495

Ref

Letter no. 02

Date 27/06/26

To,

The Principal,
Premalok Mission School,
Maa Shardapuram, Bairiya, Patna - 800007, Bihar.

Sub:- Fire Audit on Fire Safety Point of view,
Ref:- Letter no. nil dt. 20/06/2026
Sir,

With reference to above mentioned letter I inspected to the school, i.e. Premalok Mission School on 21/06/2026 for carried out Fire Audit on Fire Safety Point of view as a third party auditor which is already mentioned in Annex E 7 of NBC Part IV.

It was established in 1990 as per record, so NBC 2005 Part IV or before will be applicable on this building. NBC is applicable in Bihar state.

As per NBC guidelines this building falls under Group 'B' Educational Building.

During inspection I found that this building is G+3, below 15M in height constructed on more than 40' wide road.

I also found the following:-

- (i) ISI marked Fire Extinguishers.
- (ii) 2 Stair case
- (iii) Alternate source of electricity.
- (iv) Lift under construction
- (v) Refugee area

In addition to above the school management also conduct fire drill regularly. The watch & ward staff is aware to handle the fire extinguisher.


Suggestion:-

- (i) To hang local Fire Station telephone no. in future.
- (ii) To install Fire Exit directional sign in future.
- (iii) To install down comer in future.

Observation:-

The building is situated on more than 40' wide road where fire brigade vehicle can reach easily, nos. of exit is sufficient & first aid fire-fighting equipment is already installed, therefore this school building is safe on fire point of view.

Yours faithfully,


(Ramesh Chandra)
Sr. Fire Consultant
Fire Auditor